

**ADDENDUM NO. #1**

TO PLANS AND SPECIFICATIONS FOR

2019 LIFT STATION 36, 44 & 47 REHABILITATION PROJECT CWF19-550-07  
CITY OF WICHITA FALLS, TEXAS

August 14, 2019

**BID DATE: August 20, 2019**

---

The following changes to the plans, specifications, and contract documents for the 2019 Lift Station Rehabilitation Project, CWF19-550-07, shall supersede the appropriate parts of the original plans and specifications and shall be incorporated as part of the contract.

**Bidding Requirements:**

Bidding clarification needed. The bid date is **August 20, 2019**.

On Sheet 15 of the plans, the existing power to Lift Station 47 is **480V 3 Phase**. The Contractor shall order a 480V 3 Phase motor. Page Q-18 of the specifications correctly calls out a 480V 3 Phase motor.

**ACKNOWLEDGEMENT OF RECEIPT OF ADDENDUM NO. #1:**

\_\_\_\_\_  
(Contractor)

By: \_\_\_\_\_

CAUTION: **FAILURE TO SUBMIT THIS SIGNED ADDENDUM WITH THE BID PROPOSAL FORM WILL BE CAUSE FOR REJECTION OF BID.**

CITY OF WICHITA FALLS

  
\_\_\_\_\_  
T. Blane Boswell, P.E., City Engineer